GOVERNMENT OF KARNATAKA
DEPARTMENT OF TECHNICAL EDUCATION
GOVERNMENT ENGINEERING COLLEGE,
HAVERI

Devagiri, Haveri-581110 Phone/Fax: 08375 233657

Ref. No: GECH/EST/136/Test/2021-22 Date: 12-08-2022

To,
Secretary,
Om National Public School,
Prashanti Education Trust,
Ranebennur, Haveri Dist.

Results of NDT Compressive Strength Test

Name of work	: Prashanti Education Trust, Om Public School building, on R.S.No. 848, Hissa No. 1+2+3+4/k2, Ranebennur Town, Haveri District.
Reference No.	: ತಮ್ಮ ಕಚೇರಿ ಪತ್ರ ಸಂ. nil /2021–22 ದಿ: 08-08-2022.
Date of testing	: 10-08-2022.

Sl.No.	Items	Average compressive strength (N/mm^2)	Remarks
1	R C C Column	24	Reinforcement not observed
2	R C C Beam	26	Reinforcement not observed
3	R C C Slab	25	Reinforcement not observed

Note: This report is strictly confidential. Its use for publicity, arbitration or evidence in legal disputes is forbidden.

Staff Incharge
Department of Civil Engineering
Government Engineering College
Haveri-581110.

Scanned with CamScanner

Structural Stability Certificate

This is to certify that the work of the structural design for the building mentioned below is entrusted to me.

Name & Address of Owner :

APPLICANT:
Om School & College
Prashanti Education Trust
Ranebennur Dist:Haveri

Sanctioned Floor :

Ground Floor ,First Floor,Second Floor
& Third Floor(with RCC)

Site Address:

On R S No:848 , Plot No. 1+2+3+4/C
AT:Beside STJIT Old P B Road Ranebennur
DIST:HAVERI
Contact:9901804333

The Framed structure is designed as per IS: 456 taking into account all the lateral forces and earthquake forces.

This is to certify that the structure is **Ground Floor & First Floor -12 Years Old, & Second Floor -3 Years Old And Third Floor-2 Years Old** and is stable for its intended use and the certificate is issued based on drawings ,structural design and my periodic inspection to the site.

Place: Ranebennur
Date: 21-09-2022

ANUBHAVA CONSTRUCTIONS
Govt. Reg.
Valuer
RANEBENNUR

Signature of Valuer
21/09/22

V.F.Marbasannanavar. B.E.(Civil)FIV.,MIE.,MISTE
Consulting Civil Engineer & Contractor
Bank Approved Valuer
Govt Of India Registered Valuer
Reg No-CAT/VOL-1/387/98-99

Scanned with CamScanner